

Uvalde CISD	09-09-2026					
9-9-2026	09-09-2026					
Project type	Month					Number of completed work orders as per campus for the month
	Column2	Column3	Column4	Column5	Column6	Column 7
Work order completed for	Month		Comp. W.O.	7-1-26 thru 7-31-26		Year 2026
Anthon School- Uvalde Dual Language Academy			50			
Batesville School	August		18			
Benson-Crossroads Academy	August		27			
Dalton School	August		65			
Flores Complex	August		23			
Uvalde High School (including tennis complex)	August		71			
Morales Junior High	August		47			
Praxedis Mata Torres-West Garden School	August		0			
UCISD Administrative Complex	August		22			
Slate Creek	August		2			
Athletic Fields	August		4			
Honey Bowl	August		9			
Open extended work orders for yardwork.	August		735.5 hrs			
Food Drive assistance	August		0			
Legacy	August		15			
Year to date work orders completed	August		2906			
Work in Progress	Status	Cost of work	Board App.	Contractor	Date of work	Notes on projects in progress
Conduct 11 month walk through at the Legacy campus .	9-9-2026		no	UCISD,S&P	9-9-2026	Walk through campus to point out any problems that exist on the campus for warranty to cover.
Getting quote to replace HVAC unit in room 2 in Batesville.	in progress	\$16,428	no	Texas Chillers	in progress	Quote to replace a/c unit that has multiple problems and parts are getting hard to locate. Elementary room 2
Work on the fire alarm system to locate problem in the wiring.	in progress	\$5,862	no	Eneron	in progress	Company to come out on weekend to do wire tracing to locate communication problem on the fire alarm system.
Cleanup of the Batesville Jr High building after flooding of July	in progress	\$86,710	no	Gerloff Company	in progress	Cut out wet sheetrock and remove the floor tile from the Jr. High building after water got under door and ran under tile.
Work on the intercom systems at the UDLA campus	in progress	?	no	New Vendor		Tracing wiring to locate a bad connection or brake in com lines causing the intercom to malfunction.
Replacing pump bearings on the chill water system of the High School.	in progress	\$200. parts	no	UCISD M&O	in progress	Pulling worn bearing and replacing tem on the cold water pumps at UHS. Preventative Maintenance
foTest of exterior building materials for ACBM at campuses for records.	in progress	\$18,000	no	TASB	in progress	Sampling of all bricks and building covering that are not wood, glass or steel to update ACBM records.
Install new exhaust fans to reove hot air from MJH main halls	in progress	\$1,300	no	UCISD M&O	in progress	Adding fans to pull heat from the area where heat is stacking and causing failure of a/c units in the heat of the afternoon.
Back flow preventer testing	In progress	?	no	Sanford Water Works	In progress	Testing of all the back flow preventers at all district facilities.
Having problems with RTUs 7,11,12,15,18 at Legacy campus.	in Progress	?	no	Texas Air	In Progress	These units do not seam to be cooling as they should. Some units have been powered down at this time.
Mahindra Tractor at Tellus Equipment for engine problems	Quote	Awaiting Quote	no	Tellus Equipment	Quote	Motor problems with 35 horse tractor. Has been taken to Tellus Equipment for quote on repair.
Make repairs to drive motors at the Auditorium Stage and 2 AHU	Completed	\$261	no	Completed	in progress	Starter heater are week and letting unit shut down. New heaters on the way.
Instalation of donated water fountains at Dalton School	in progress	\$2,910	yes	UCISD M&O	in progress	Waiting for testing of wall materials and bricks as per State and Fedral requirements Safety
Southland Industries, formerly Brandt to make chiller repairs	parts ordered	\$24,768	no	Southland Ind.	parts ordered	Unit running on A bank. B bank is waiting on a new control board. Waiting on Carrier Corp. to program board.
Schneider electric Led light conversion.	Finish soon	\$4,000,000	yes	Schneider electric	Finish soon	Going back over areas and checking for anything missed or warranty work needed to be done.
Schneidr Electric BAS conversion	In Progress	Part of above	yes	Schneider electric	In Progress	Replacement of BAS controls at selected campuses to take the place of aged controls that are outdated
Start test Legacy School for Asbestos for the Abestos management plan	to begin	\$3,268	no	TASB	Make appt.	Will arrange to start testing of all materials in new school that are not solid wood, steel, or glass.
Price to rekey the Uvalde High School	Approval	\$216,422	Approval	Allegion .Acme Hardware	Approval	Rekey of the entire UHS campus awaiting approval.
Continued repairs to the exterior Doors that may be safety hazzard.	Continuing		no	M&O UCISD	Continuing	Make repairs to the exterior doors and gates to make sure the campus stays secure, even if covered by warrenty.
Installation of key warden sysytem at campuses	training	\$48,481	no	KeyWarden Systems	Training	Tuesday the 4th of Aug. is training day for the system for maintenance team.
Check on the status of punchlist items not done at Legacy School	In Progress	?	no	UCISD M&O	in Progress	Check on list of items at the Legacy Campus that were not finished or done to satisfaction before warrenty period runs out.
Check on the status of punch list items in the vestibules at campuses	In Progress	?	no	UCISD M&O	In Progress	Check on a list of items not finished in the vestibule project or not up to standards before the warrenty period runs out.
Alphanumeric identification of campus buildings- doors-gates-windows	in progress	\$25,031	no	M&O UCISD	in progress	Identify all building- doors-gates-windows on all campuses (phase 1) building ID.
Look into price to rekey the llegacy School due to lost keyring.	in progress	?	no	UCISD M&O	in Progress	Getting prices on cost to rekey the Legacy campus due to a lost set of keys. Starting with the outer doors and gates.
WO# 73701 and 73793, secure electrical panels and disconnect boxes	in progress	\$9,786	no	M&O UCISD	in progress	Secure all electrical boxes and panels with same keyed locks district wide as per Slidesoft safety stated (one campus at a time)
Pest control cost for month (Bugco, Food Service Kitchens)	On Going	\$300	no	BUGCO	On Going	Cost of pest control in food service areas.
Pest control cost for month (Medina pest control. Non food service areas)	On Going	\$1,420	no	Medina Pest Control	On Going	Cost of pest control services in all other areas that are not food service kitchen related.
Paint new doors in district. Only at times when students are on a break.	In Progress	\$1,833	no	UCISD M&O	In Progress	Clean, prime and paint the new doors at various campuses that have been installed to replace damaged doors.