

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Woodridge SD 68	COUNTY Dupage
FACILITY NAME Thomas Jefferson Jr High School	FACILITY LOCATION 7200 Janes Ave, Woodridge

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/23/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
14	Administration and General	Room 114 - Maintain clearance above storage.
16	Administration and General	Large cart blocking access to fire extinguisher in hall near Fitness Center. Please move.
24	Administration and General	In Room 114, there is an extension cord plugged into a classroom outlet and extending into the closet with some appliances plugged into it. Please remove. Art Room closet - Two power strips are daisy chained together. Please remove.
230	Science Laboratories	Room 114 - The chemical storage room needs general housekeeping. Also, the dedicated cabinet needs to be used for any flammable chemicals and kept locked. The pod storage area also needs general housekeeping, and the microwave needs to be moved.

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Woodridge SD 68	COUNTY Dupage
FACILITY NAME Edgewood Elem School	FACILITY LOCATION 7900 Woodridge Dr, Woodridge

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/23/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
4	Administration and General	LRC closet was open allowing access to a laptop charging station. Keep closet door closed and move charging station out of the closet.
14	Administration and General	LRC closet needs to be cleaned up including keeping appropriate clearance above storage. Maintain clearance above storage in Art Room.
95	Classrooms	Room 224 - Keep door glass vision panel clear.

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Woodridge SD 68	COUNTY Dupage
FACILITY NAME Goodrich Elem School	FACILITY LOCATION 3450 Hobson Rd, Woodridge

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/22/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
22	Administration and General	Art Room - Remove fabric material that is covering lower bookcases.
192	Library/Media Center (A)	Exit signs not illuminated. Please correct.
193	Library/Media Center (A)	Emergency lighting needs to be addressed.

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Woodridge SD 68	COUNTY Dupage
FACILITY NAME Meadowview Elem School	FACILITY LOCATION 2525 Mitchell Dr, Woodridge

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/22/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
14	Administration and General	Workroom 305 - General housekeeping is needed including appropriate clearance above storage.

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Woodridge SD 68	COUNTY Dupage
FACILITY NAME William F Murphy Elem School	FACILITY LOCATION 7700 Larchwood Ln, Woodridge

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/22/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
14	Administration and General	Maintain clearance above storage in Art Room, Room 103, and Room 112. Please monitor storage above in all spaces.

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Woodridge SD 68	COUNTY Dupage
FACILITY NAME John L Siplely Elem School	FACILITY LOCATION 2806 83rd St, Woodridge

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/23/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
14	Administration and General	Maintain clearance above storage in Art Room.

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Woodridge SD 68	COUNTY Dupage
FACILITY NAME Willow Creek Elem School	FACILITY LOCATION 2901 Jackson Dr, Woodridge

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/22/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
22	Administration and General	Room 128 - Remove rugs that are not fire rated. Room 127 - Remove window coverings that are not fire rated.